

**Project Number:** MICRO-CLIMAT

**Project Name:**

**Location:**

**Date:** March 03, 2017

**Prepared By:**

**Floor Plan:** Basement

**Circuit Information:**

**Total Length:** 1,905 ft - Barrier PEX 1/2"

Circuit	Length	Manifold	Tube Type
A-1	283	Manifold 1	1/2"
A-2	286	Manifold 1	1/2"
A-3	283	Manifold 1	1/2"
A-4	296	Manifold 1	1/2"
A-5	303	Manifold 1	1/2"
A-6	252	Manifold 1	1/2"
A-7	202	Manifold 1	1/2"



**Load Short Form**  
**Entire House**  
 Fresh Air Corporation

Job: 456  
 Date: October 1, 2006  
 By: John Contractor

**Project Information**

For: Mr. and Ms. Smith  
 1 Easy Lane, Perfect, ST 12345  
 Phone: 555-555-5555 Fax: 555-555-5556  
 Email: smiths@email.com

**Design Information**

	Htg	Clg	Infiltration	
Outside db (°F)	63	88	Method	Simplified
Inside db (°F)	68	75	Construction quality	Average
Design TD (°F)	5	13	Fireplaces	0
Daily range	-	L		
Inside humidity (%)	-	50		
Moisture difference (gr/lb)	-	33		

**HEATING EQUIPMENT**

Make  
 Trade  
 Model

Efficiency 80 AFUE  
 Heating input 0 Btuh  
 Heating output 0 Btuh  
 Temperature rise 0 °F  
 Actual air flow 505 cfm  
 Air flow factor 0.175 cfm/Btuh  
 Static pressure 0.50 in H2O  
 Space thermostat

**COOLING EQUIPMENT**

Make  
 Trade  
 Cond  
 Coil

Efficiency 0 EER  
 Sensible cooling 0 Btuh  
 Latent cooling 0 Btuh  
 Total cooling 0 Btuh  
 Actual air flow 505 cfm  
 Air flow factor 0.042 cfm/Btuh  
 Static pressure 0.50 in H2O  
 Load sensible heat ratio 0.87

ROOM NAME	Area (ft²)	Htg load (Btuh)	Clg load (Btuh)	Htg AVF (cfm)	Clg AVF (cfm)
Living room	150	297	2263	52	95
Dining	140	261	892	46	37
Kitchen	165	345	2086	60	88
Bedroom 1	180	376	1307	66	55
Hall	130	121	423	21	18
Master	240	310	854	54	36
Laundry	77	163	365	29	15
Bedroom 2	168	251	646	44	27
Master Bath	60	142	306	25	13
Office	100	106	323	19	14
Room28	230	212	698	37	29
Mudroom	110	298	1867	52	78

Printout certified by ACCA to meet all requirements of Manual J 8th Ed.

Entire House	1750	2882	12031	505	505
Other equip loads		296	384		
Equip. @ 0.93 RSM			11583		
Latent cooling			1874		
TOTALS	1750	3178	13457	505	505

Printout certified by ACCA to meet all requirements of Manual J 8th Ed.



**Building Analysis**  
**Entire House**  
 Fresh Air Corporation

Job: 456  
 Date: October 1, 2006  
 By: John Contractor

**Project Information**


For: Mr. and Ms. Smith  
 1 Easy Lane, Perfect, ST 12345  
 Phone: 555-555-5555 Fax: 555-555-5556  
 Email: smiths@email.com

**Design Conditions**

<b>Location:</b> Honolulu, HI, US Elevation: 16 ft Latitude: 21°N			<b>Indoor:</b> Indoor temperature (°F) Design TD (°F) Relative humidity (%) Moisture difference (gr/lb)	<b>Heating</b> 68 5 50 -18.0	<b>Cooling</b> 75 13 50 32.5
<b>Outdoor:</b> Dry bulb (°F) Daily range (°F) Wet bulb (°F) Wind speed (mph)	<b>Heating</b> 63 - - 15.0	<b>Cooling</b> 88 12 ( L ) 73 7.5	<b>Infiltration:</b> Method Construction quality Fireplaces		Simplified Average 0


**Heating**

Component	Btuh/ft²	Btuh	% of load
Walls	0.4	664	20.9
Glazing	2.8	388	12.2
Doors	1.9	109	3.4
Ceilings	0.2	140	4.4
Floors	0.0	24	0.8
Infiltration	0.3	366	11.5
Ducts		1191	37.5
Piping		152	4.8
Humidification		0	0.0
Ventilation		144	4.5
Adjustments		0	0
<b>Total</b>		<b>3178</b>	<b>100.0</b>



**Cooling**

Component	Btuh/ft²	Btuh	% of load
Walls	0.8	1409	11.3
Glazing	35.0	4758	38.3
Doors	11.2	627	5.0
Ceilings	1.7	1462	11.8
Floors	0.0	0	0.0
Infiltration	0.4	512	4.1
Ducts		3263	26.3
Ventilation		384	3.1
Internal gains		0	0.0
Blower		0	0.0
Adjustments		0	0
<b>Total</b>		<b>12414</b>	<b>100.0</b>



Overall U-value = 0.065 Btuh/ft²-°F

Data entries checked.



**Component Constructions**  
**Entire House**  
 Fresh Air Corporation

Job: 456  
 Date: October 1, 2006  
 By: John Contractor

**Project Information**

For: Mr. and Ms. Smith  
 1 Easy Lane, Perfect, ST 12345  
 Phone: 555-555-5555 Fax: 555-555-5556  
 Email: smiths@email.com

**Design Conditions**

<b>Location:</b> Honolulu, HI, US Elevation: 16 ft Latitude: 21°N			<b>Indoor:</b> Indoor temperature (°F) Design TD (°F) Relative humidity (%) Moisture difference (gr/lb)	<b>Heating</b> 68 5 50 -18.0	<b>Cooling</b> 75 13 50 32.5
<b>Outdoor:</b> Dry bulb (°F) Daily range (°F) Wet bulb (°F) Wind speed (mph)	<b>Heating</b> 63 - - 15.0	<b>Cooling</b> 88 12 ( L ) 73 7.5	<b>Infiltration:</b> Method Construction quality Fireplaces	Simplified Average 0	

**Construction descriptions**

**Walls**

15B-10sfc-2: Basement - 8" concrete, no framing or interior finish, R-10 foam bd to floor, 2'

Or	Area ft²	U-value Btuh/ft²·°F	Insul R ft²·°F/Btuh	Htg HTM Btuh/ft²	Loss Btuh	Clg HTM Btuh/ft²	Gain Btuh
n	492	0.061	10.0	0.38	189	0.81	397
e	368	0.061	10.0	0.39	142	0.82	303
s	484	0.061	10.0	0.38	185	0.80	388
w	384	0.061	10.0	0.39	148	0.83	321
all	1728	0.061	10.0	0.38	664	0.82	1409

**Partitions**

(none)

**Windows**

1D-c2ow: Operable, clear glass, wood frame, 2 pane

n	40	0.570	0.0	2.85	114	19.3	773
e	32	0.570	0.0	2.85	91	61.4	1965
s	48	0.570	0.0	2.85	137	21.6	1039
w	16	0.570	0.0	2.85	46	61.4	982
all	136	0.570	0.0	2.85	388	35.0	4758

**Doors**

11D0: Wood door, solid core, no storm

n	28	0.390	0.0	1.95	55	11.2	313
s	28	0.390	0.0	1.95	55	11.2	313
all	56	0.390	0.0	1.95	109	11.2	627

**Ceilings**

16B-30ad: Ceiling under vented attic, no radiant barrier, dark shingles, R-30 insulation

	875	0.032	30.0	0.16	140	1.67	1462
--	-----	-------	------	------	-----	------	------

**Floors**

41B0: Radiant panel over basement, 3/4" ply subflr, Omega heat xfer plates

	555	0.000	0.0	0.00	0	0.00	0
--	-----	-------	-----	------	---	------	---

21B-28t: Tile covered basement floor, R-3 or higher insul, 28' wide

	320	0.015	3.0	0.07	24	0.00	0
--	-----	-------	-----	------	----	------	---





**Project Summary**  
**Entire House**  
 Fresh Air Corporation

Job: 456  
 Date: October 1, 2006  
 By: John Contractor

**Project Information**

For: Mr. and Ms. Smith  
 1 Easy Lane, Perfect, ST 12345  
 Phone: 555-555-5555 Fax: 555-555-5556  
 Email: smiths@email.com  
 Notes: Location known for high winds.

**Design Information**

Weather: Honolulu, HI, US

**Winter Design Conditions**

Outside db 63 °F  
 Inside db 68 °F  
 Design TD 5 °F

**Summer Design Conditions**

Outside db 88 °F  
 Inside db 75 °F  
 Design TD 13 °F  
 Daily range L  
 Relative humidity 50 %  
 Moisture difference 33 gr/lb

**Heating Summary**

Structure 1691 Btuh  
 Ducts 1191 Btuh  
 Central vent (26 cfm) 144 Btuh  
 Humidification 0 Btuh  
 Piping 152 Btuh  
 Equipment load 3178 Btuh

**Sensible Cooling Equipment Load Sizing**

Structure 8767 Btuh  
 Ducts 3263 Btuh  
 Central vent (26 cfm) 384 Btuh  
 Blower 0 Btuh  
 Use manufacturer's data n  
 Rate/swing multiplier 0.93  
 Equipment sensible load 11583 Btuh

**Infiltration**

Method Simplified  
 Construction quality Average  
 Fireplaces 0

	Heating	Cooling
Area (ft <sup>2</sup> )	1750	1750
Volume (ft <sup>3</sup> )	10500	10500
Air changes/hour	0.38	0.20
Equiv. AVF (cfm)	67	35

**Latent Cooling Equipment Load Sizing**

Structure 773 Btuh  
 Ducts 521 Btuh  
 Central vent (26 cfm) 580 Btuh  
 Equipment latent load 1874 Btuh  
 Equipment total load 13457 Btuh  
 Req. total capacity at 0.70 SHR 1.4 ton

**Heating Equipment Summary**

Make  
 Trade  
 Model

Efficiency 80 AFUE  
 Heating input 0 Btuh  
 Heating output 0 Btuh  
 Temperature rise 0 °F  
 Actual air flow 505 cfm  
 Air flow factor 0.175 cfm/Btuh  
 Static pressure 0.50 in H2O  
 Space thermostat

**Cooling Equipment Summary**

Make  
 Trade  
 Cond  
 Coil

Efficiency 0 EER  
 Sensible cooling 0 Btuh  
 Latent cooling 0 Btuh  
 Total cooling 0 Btuh  
 Actual air flow 505 cfm  
 Air flow factor 0.042 cfm/Btuh  
 Static pressure 0.50 in H2O  
 Load sensible heat ratio 0.87

Printout certified by ACCA to meet all requirements of Manual J 8th Ed.





**AED Assessment**  
**Entire House**  
 Fresh Air Corporation

Job: 456  
 Date: October 1, 2006  
 By: John Contractor

**Project Information**


For: Mr. and Ms. Smith  
 1 Easy Lane, Perfect, ST 12345  
 Phone: 555-555-5555 Fax: 555-555-5556  
 Email: smiths@email.com

**Design Conditions**

<b>Location:</b>		<b>Indoor:</b>		<b>Heating</b>	<b>Cooling</b>
Honolulu, HI, US		Indoor temperature (°F)		68	75
Elevation:	16 ft	Design TD (°F)		5	13
Latitude:	21°N	Relative humidity (%)		50	50
<b>Outdoor:</b>		Moisture difference (gr/lb)		-18.0	32.5
	<b>Heating</b>	<b>Cooling</b>	<b>Infiltration:</b>		
Dry bulb (°F)	63	88			
Daily range (°F)	-	12 ( L )			
Wet bulb (°F)	-	73			
Wind speed (mph)	15.0	7.5			

**Test for Adequate Exposure Diversity**

**Hourly Glazing Load**



**Maximum hourly glazing load exceeds average by 13.1%.**

**House has adequate exposure diversity (AED), based on AED limit of 30%.**

**AED excursion: 0 Btuh**



**Right-J Worksheet**  
**Entire House**  
 Fresh Air Corporation

**Job:** 456  
**Date:** October 1, 2006  
**By:** John Contractor

1 Room name		Entire House							Living room					
2 Exposed wall		240.0 ft							25.0 ft					
3 Ceiling height		8.0 ft							8.0 ft					
4 Room dimensions									10.0 x 15.0 ft					
5 Room area		1750.0 ft <sup>2</sup>							150.0 ft <sup>2</sup>					
	Ty	Construction number	U-value (Btuh/ft <sup>2</sup> -F)	Or	HTM (Btuh/ft <sup>2</sup> )		Area (ft <sup>2</sup> ) or perimeter (ft)		Load (Btuh)		Area (ft <sup>2</sup> ) or perimeter (ft)		Load (Btuh)	
					Heat	Cool	Gross	N/P/S	Heat	Cool	Gross	N/P/S	Heat	Cool
6	W	15B-10sfc-2	0.083	n	0.31	1.13	560	492	189	397	80	72	28	59
	G	1D-c2ow	0.570	n	2.85	19.32	40	0	114	773	8	0	23	155
	D	11D0	0.390	n	1.95	11.19	28	28	55	313	0	0	0	0
	W	15B-10sfc-2	0.083	e	0.31	1.13	400	368	142	303	0	0	0	0
11	G	1D-c2ow	0.570	e	2.85	61.39	32	0	91	1965	0	0	0	0
	W	15B-10sfc-2	0.083	s	0.31	1.13	560	484	185	388	0	0	0	0
	G	1D-c2ow	0.570	s	2.85	21.64	48	0	137	1039	0	0	0	0
	D	11D0	0.390	s	1.95	11.19	28	28	55	313	0	0	0	0
	W	15B-10sfc-2	0.083	w	0.31	1.13	400	384	148	321	120	104	40	84
	G	1D-c2ow	0.570	w	2.85	61.39	16	0	46	982	16	0	46	982
	C	16B-30ad	0.032	-	0.16	1.67	875	875	140	1462	0	0	0	0
	F	41B0	0.047	-	0.00	0.00	555	78	0	0	150	25	0	0
	F	21B-28t	0.015	-	0.07	0.00	320	42	24	0	0	0	0	0
6	c) AED excursion													317
	Envelope loss/gain								1325	8256			136	1596
12	a) Infiltration								366	512			38	53
	b) Room ventilation								0	0			0	0
13	Internal gains:		Occupants @	230			0			0	0			0
			Appliances @	1200			0			0	0			0
	Subtotal (lines 6 to 13)								1691	8767			174	1649
	Less external load								0	0			0	0
	Less transfer								0	0			0	0
	Redistribution								0	0			0	0
14	Subtotal								1691	8767			174	1649
15	Duct loads						70%	37%	1191	3263	70%	37%	123	614
	Total room load								2882	12031			297	2263
	Air required (cfm)								505	505			52	95

Printout certified by ACCA to meet all requirements of Manual J 8th Ed.







**Right-J Worksheet**  
**Entire House**  
**Fresh Air Corporation**

**Job: 456**  
**Date: October 1, 2006**  
**By: John Contractor**

1 Room name				Dining 14.0 ft				Kitchen 26.0 ft						
2 Exposed wall				8.0 ft heat/cool				8.0 ft heat/cool						
3 Ceiling height				14.0 x 10.0 ft				11.0 x 15.0 ft						
4 Room dimensions				140.0 ft <sup>2</sup>				165.0 ft <sup>2</sup>						
5 Room area														
	Ty	Construction number	U-value (Btuh/ft <sup>2</sup> -F)	Or	HTM (Btuh/ft <sup>2</sup> )		Area (ft <sup>2</sup> ) or perimeter (ft)		Load (Btuh)		Area (ft <sup>2</sup> ) or perimeter (ft)		Load (Btuh)	
					Heat	Cool	Gross	N/P/S	Heat	Cool	Gross	N/P/S	Heat	Cool
6	W	15B-10sfc-2	0.083	n	0.31	1.13	112	80	30	59	88	60	22	43
	G	1D-c2ow	0.570	n	2.85	19.32	32	0	91	618	0	0	0	0
	D	11D0	0.390	n	1.95	11.19	0	0	0	0	28	28	55	313
11	W	15B-10sfc-2	0.083	e	0.31	1.13	0	0	0	0	120	104	40	84
	G	1D-c2ow	0.570	e	2.85	61.39	0	0	0	0	16	0	46	982
	W	15B-10sfc-2	0.083	s	0.31	1.13	0	0	0	0	0	0	0	0
	G	1D-c2ow	0.570	s	2.85	21.64	0	0	0	0	0	0	0	0
	D	11D0	0.390	s	1.95	11.19	0	0	0	0	0	0	0	0
	W	15B-10sfc-2	0.083	w	0.31	1.13	0	0	0	0	0	0	0	0
	G	1D-c2ow	0.570	w	2.85	61.39	0	0	0	0	0	0	0	0
	C	16B-30ad	0.032	-	0.16	1.67	0	0	0	0	0	0	0	0
	F	41B0	0.047	-	0.00	0.00	0	0	0	0	165	26	0	0
	F	21B-28t	0.015	-	0.07	0.00	140	14	10	0	0	0	0	0
6	c) AED excursion													43
	Envelope loss/gain								132	620			163	1465
12	a) Infiltration								21	30			40	55
	b) Room ventilation								0	0			0	0
13	Internal gains:		Occupants @	230			0			0	0			0
			Appliances @	1200			0			0	0			0
	Subtotal (lines 6 to 13)								153	650			202	1520
	Less external load								0	0			0	0
	Less transfer								0	0			0	0
	Redistribution								0	0			0	0
14	Subtotal								153	650			202	1520
15	Duct loads						70%	37%	108	242	70%	37%	142	566
	Total room load								261	892			345	2086
	Air required (cfm)								46	37			60	88

Printout certified by ACCA to meet all requirements of Manual J 8th Ed.





**Right-J Worksheet**  
**Entire House**  
**Fresh Air Corporation**

**Job: 456**  
**Date: October 1, 2006**  
**By: John Contractor**

1 Room name				Bedroom 1				Hall						
2 Exposed wall				28.0 ft				6.0 ft						
3 Ceiling height				8.0 ft heat/cool				8.0 ft heat/cool						
4 Room dimensions				18.0 x 10.0 ft				1.0 x 130.0 ft						
5 Room area				180.0 ft <sup>2</sup>				130.0 ft <sup>2</sup>						
	Ty	Construction number	U-value (Btuh/ft <sup>2</sup> -F)	Or	HTM (Btuh/ft <sup>2</sup> )		Area (ft <sup>2</sup> ) or perimeter (ft)		Load (Btuh)		Area (ft <sup>2</sup> ) or perimeter (ft)		Load (Btuh)	
					Heat	Cool	Gross	N/P/S	Heat	Cool	Gross	N/P/S	Heat	Cool
6	W	15B-10sfc-2	0.083	n	0.31	1.13	0	0	0	0	0	0	0	0
	G	1D-c2ow	0.570	n	2.85	19.32	0	0	0	0	0	0	0	0
	D	11D0	0.390	n	1.95	11.19	0	0	0	0	0	0	0	0
	W	15B-10sfc-2	0.083	e	0.31	1.13	0	0	0	0	0	0	0	0
11	G	1D-c2ow	0.570	e	2.85	61.39	0	0	0	0	0	0	0	0
	W	15B-10sfc-2	0.083	s	0.31	1.13	144	112	43	86	48	20	7	9
	G	1D-c2ow	0.570	s	2.85	21.64	32	0	91	692	0	0	0	0
	D	11D0	0.390	s	1.95	11.19	0	0	0	0	28	28	55	313
	W	15B-10sfc-2	0.083	w	0.31	1.13	80	80	31	68	0	0	0	0
	G	1D-c2ow	0.570	w	2.85	61.39	0	0	0	0	0	0	0	0
	C	16B-30ad	0.032	-	0.16	1.67	0	0	0	0	0	0	0	0
	F	41B0	0.047	-	0.00	0.00	0	0	0	0	130	6	0	0
	F	21B-28t	0.015	-	0.07	0.00	180	28	13	0	0	0	0	0
6	c) AED excursion									47				-27
	Envelope loss/gain								178	893			62	295
12	a) Infiltration								43	60			9	13
	b) Room ventilation								0	0			0	0
13	Internal gains:		Occupants @	230	0				0	0			0	0
			Appliances @	1200	0				0	0			0	0
	Subtotal (lines 6 to 13)								221	953			71	308
	Less external load								0	0			0	0
	Less transfer								0	0			0	0
	Redistribution								0	0			0	0
14	Subtotal								221	953			71	308
15	Duct loads						70%	37%	156	355	70%	37%	50	115
	Total room load								376	1307			121	423
	Air required (cfm)								66	55			21	18

Printout certified by ACCA to meet all requirements of Manual J 8th Ed.





# Right-J Worksheet Entire House Fresh Air Corporation

**Job:** 456  
**Date:** October 1, 2006  
**By:** John Contractor

1 Room name				Master 31.0 ft 8.0 ft      heat/cool 16.0 x 15.0 ft 240.0 ft <sup>2</sup>				Laundry 18.0 ft 8.0 ft      heat/cool 7.0 x 11.0 ft 77.0 ft <sup>2</sup>					
2 Exposed wall				HTM (Btuh/ft <sup>2</sup> )		Area (ft <sup>2</sup> ) or perimeter (ft)		Load (Btuh)		Area (ft <sup>2</sup> ) or perimeter (ft)		Load (Btuh)	
3 Ceiling height				Heat	Cool	Gross	N/P/S	Heat	Cool	Gross	N/P/S	Heat	Cool
4 Room dimensions													
5 Room area													
Ty	Construction number	U-value (Btuh/ft <sup>2</sup> ·F)	Or										
6	W 15B-10sfc-2	0.083	n	0.31	1.13	128	128	50	108	56	56	22	47
	G 1D-c2ow	0.570	n	2.85	19.32	0	0	0	0	0	0	0	0
	D 11D0	0.390	n	1.95	11.19	0	0	0	0	0	0	0	0
11	W 15B-10sfc-2	0.083	e	0.31	1.13	0	0	0	0	88	88	34	75
	G 1D-c2ow	0.570	e	2.85	61.39	0	0	0	0	0	0	0	0
	W 15B-10sfc-2	0.083	s	0.31	1.13	0	0	0	0	0	0	0	0
	G 1D-c2ow	0.570	s	2.85	21.64	0	0	0	0	0	0	0	0
	D 11D0	0.390	s	1.95	11.19	0	0	0	0	0	0	0	0
	W 15B-10sfc-2	0.083	w	0.31	1.13	120	120	46	102	0	0	0	0
	G 1D-c2ow	0.570	w	2.85	61.39	0	0	0	0	0	0	0	0
	C 16B-30ad	0.032	-	0.16	1.67	240	240	38	401	77	77	12	129
	F 41B0	0.047	-	0.00	0.00	0	0	0	0	0	0	0	0
	F 21B-28t	0.015	-	0.07	0.00	0	0	0	0	0	0	0	0
6	c) AED excursion								-54				-23
	Envelope loss/gain							135	556			68	227
12	a) Infiltration							47	66			27	38
	b) Room ventilation							0	0			0	0
13	Internal gains:		Occupants @	230	0			0	0	0	0	0	0
			Appliances @	1200	0			0	0	0	0	0	0
	Subtotal (lines 6 to 13)							182	623			96	266
	Less external load							0	0			0	0
	Less transfer							0	0			0	0
	Redistribution							0	0			0	0
14	Subtotal							182	623			96	266
15	Duct loads				70%	37%		128	232	70%	37%	67	99
	Total room load							310	854			163	365
	Air required (cfm)							54	36			29	15

Printout certified by ACCA to meet all requirements of Manual J 8th Ed.





**Right-J Worksheet**  
**Entire House**  
 Fresh Air Corporation

**Job:** 456  
**Date:** October 1, 2006  
**By:** John Contractor

1 Room name				Bedroom 2				Master Bath						
2 Exposed wall				26.0 ft				16.0 ft						
3 Ceiling height				8.0 ft heat/cool				8.0 ft heat/cool						
4 Room dimensions				12.0 x 14.0 ft				6.0 x 10.0 ft						
5 Room area				168.0 ft <sup>2</sup>				60.0 ft <sup>2</sup>						
	Ty	Construction number	U-value (Btuh/ft <sup>2</sup> -°F)	Or	HTM (Btuh/ft <sup>2</sup> )		Area (ft <sup>2</sup> ) or perimeter (ft)		Load (Btuh)		Area (ft <sup>2</sup> ) or perimeter (ft)		Load (Btuh)	
					Heat	Cool	Gross	N/P/S	Heat	Cool	Gross	N/P/S	Heat	Cool
6	W	15B-10sfc-2	0.083	n	0.31	1.13	0	0	0	0	0	0	0	0
	G	1D-c2ow	0.570	n	2.85	19.32	0	0	0	0	0	0	0	0
	D	11D0	0.390	n	1.95	11.19	0	0	0	0	0	0	0	0
11	W	15B-10sfc-2	0.083	e	0.31	1.13	112	112	43	95	0	0	0	0
	G	1D-c2ow	0.570	e	2.85	61.39	0	0	0	0	0	0	0	0
	W	15B-10sfc-2	0.083	s	0.31	1.13	96	96	37	81	48	48	19	41
	G	1D-c2ow	0.570	s	2.85	21.64	0	0	0	0	0	0	0	0
	D	11D0	0.390	s	1.95	11.19	0	0	0	0	0	0	0	0
	W	15B-10sfc-2	0.083	w	0.31	1.13	0	0	0	0	80	80	31	68
	G	1D-c2ow	0.570	w	2.85	61.39	0	0	0	0	0	0	0	0
	C	16B-30ad	0.032	-	0.16	1.67	168	168	27	281	60	60	10	100
	F	41B0	0.047	-	0.00	0.00	0	0	0	0	0	0	0	0
	F	21B-28t	0.015	-	0.07	0.00	0	0	0	0	0	0	0	0
6	c) AED excursion													
	Envelope loss/gain								107	416			59	189
12	a) Infiltration								40	55			24	34
	b) Room ventilation								0	0			0	0
13	Internal gains:		Occupants @	230			0			0	0			0
			Appliances @	1200			0			0	0			0
	Subtotal (lines 6 to 13)								147	471			84	223
	Less external load								0	0			0	0
	Less transfer								0	0			0	0
	Redistribution								0	0			0	0
14	Subtotal								147	471			84	223
15	Duct loads						70%	37%	104	175	70%	37%	59	83
	Total room load								251	646			142	306
	Air required (cfm)								44	27			25	13

Printout certified by ACCA to meet all requirements of Manual J 8th Ed.





**Right-J Worksheet**  
**Entire House**  
**Fresh Air Corporation**

**Job: 456**  
**Date: October 1, 2006**  
**By: John Contractor**

1 Room name				Office 10.0 ft 8.0 ft 10.0 x 10.0 ft heat/cool 100.0 ft <sup>2</sup>				Room28 19.0 ft 8.0 ft 1.0 x 230.0 ft heat/cool 230.0 ft <sup>2</sup>						
2 Exposed wall				HTM (Btuh/ft <sup>2</sup> )		Area (ft <sup>2</sup> ) or perimeter (ft)		Load (Btuh)		Area (ft <sup>2</sup> ) or perimeter (ft)		Load (Btuh)		
3 Ceiling height				Heat	Cool	Gross	N/P/S	Heat	Cool	Gross	N/P/S	Heat	Cool	
4 Room dimensions				U-value (Btuh/ft <sup>2</sup> ·°F)		Or								
5 Room area														
6	W	15B-10sfc-2	0.083	n	0.31	1.13	0	0	0	0	96	96	37	81
	G	1D-c2ow	0.570	n	2.85	19.32	0	0	0	0	0	0	0	0
	D	11D0	0.390	n	1.95	11.19	0	0	0	0	0	0	0	0
11	W	15B-10sfc-2	0.083	e	0.31	1.13	0	0	0	0	0	0	0	0
	G	1D-c2ow	0.570	e	2.85	61.39	0	0	0	0	0	0	0	0
	W	15B-10sfc-2	0.083	s	0.31	1.13	80	80	31	68	56	56	22	47
	G	1D-c2ow	0.570	s	2.85	21.64	0	0	0	0	0	0	0	0
	D	11D0	0.390	s	1.95	11.19	0	0	0	0	0	0	0	0
	W	15B-10sfc-2	0.083	w	0.31	1.13	0	0	0	0	0	0	0	0
	G	1D-c2ow	0.570	w	2.85	61.39	0	0	0	0	0	0	0	0
	C	16B-30ad	0.032	-	0.16	1.67	100	100	16	167	230	230	37	384
	F	41B0	0.047	-	0.00	0.00	0	0	0	0	0	0	0	0
	F	21B-28t	0.015	-	0.07	0.00	0	0	0	0	0	0	0	0
6	c) AED excursion													
	Envelope loss/gain								47	214			96	468
12	a) Infiltration								15	21			29	41
	b) Room ventilation								0	0			0	0
13	Internal gains:		Occupants @	230			0			0	0			0
			Appliances @	1200			0			0	0			0
	Subtotal (lines 6 to 13)								62	236			125	509
	Less external load								0	0			0	0
	Less transfer								0	0			0	0
	Redistribution								0	0			0	0
14	Subtotal								62	236			125	509
15	Duct loads						70%	37%	44	88	70%	37%	88	189
	Total room load								106	323			212	698
	Air required (cfm)								19	14			37	29

Printout certified by ACCA to meet all requirements of Manual J 8th Ed.



**Right-J Worksheet**  
**Entire House**  
**Fresh Air Corporation**

**Job:** 456  
**Date:** October 1, 2006  
**By:** John Contractor

1 Room name					Mudroom									
2 Exposed wall					21.0 ft									
3 Ceiling height					8.0 ft					heat/cool				
4 Room dimensions					110.0 ft <sup>2</sup> x 10.0 ft									
5 Room area					110.0 ft <sup>2</sup>									
	Ty	Construction number	U-value (Btuh/ft <sup>2</sup> -°F)	Or	HTM (Btuh/ft <sup>2</sup> )		Area (ft <sup>2</sup> ) or perimeter (ft)		Load (Btuh)		Area or perimeter		Load	
					Heat	Cool	Gross	N/P/S	Heat	Cool	Gross	N/P/S	Heat	Cool
6	W	15B-10sfc-2	0.083	n	0.31	1.13	0	0	0	0				
	G	1D-c2ow	0.570	n	2.85	19.32	0	0	0	0				
	D	11D0	0.390	n	1.95	11.19	0	0	0	0				
11	W	15B-10sfc-2	0.083	e	0.31	1.13	80	64	24	50				
	G	1D-c2ow	0.570	e	2.85	61.39	16	0	46	982				
	W	15B-10sfc-2	0.083	s	0.31	1.13	88	72	27	56				
	G	1D-c2ow	0.570	s	2.85	21.64	16	0	46	346				
	D	11D0	0.390	s	1.95	11.19	0	0	0	0				
	W	15B-10sfc-2	0.083	w	0.31	1.13	0	0	0	0				
	G	1D-c2ow	0.570	w	2.85	61.39	0	0	0	0				
	C	16B-30ad	0.032	-	0.16	1.67	0	0	0	0				
	F	41B0	0.047	-	0.00	0.00	110	21	0	0				
	F	21B-28t	0.015	-	0.07	0.00	0	0	0	0				
6	c) AED excursion									-119				
	Envelope loss/gain								143	1316				
12	a) Infiltration								32	45				
	b) Room ventilation								0	0				
13	Internal gains:		Occupants @	230			0			0				
			Appliances @	1200			0			0				
	Subtotal (lines 6 to 13)								175	1361				
	Less external load								0	0				
	Less transfer								0	0				
	Redistribution								0	0				
14	Subtotal								175	1361				
15	Duct loads						70%	37%	123	506				
	Total room load								298	1867				
	Air required (cfm)								52	78				

Printout certified by ACCA to meet all requirements of Manual J 8th Ed.



# Radiant Heating Tubing Requirements

Job: 456  
Date: October 1, 2006  
By: John Contractor

Fresh Air Corporation

## Project Information

For: Mr. and Ms. Smith  
1 Easy Lane, Perfect, ST 12345  
Phone: 555-555-5555 Fax: 555-555-5556  
Email: smiths@email.com

## Tubing Requirements

Roll 1: 600 ft 3/8" BPEX (Part # WX-BP3-600)	4 lengths 113 ft waste	
Living room-A: 127 ft	Living room-B: 141 ft	Hall-A: 116 ft
Hall-B: 104 ft		
Roll 2: 600 ft 3/8" BPEX (Part # WX-BP3-600)	3 lengths 118 ft waste	
Mudroom: 191 ft	Kitchen-A: 148 ft	Kitchen-B: 144 ft



# Radiant Heating Design Summary

Job: 456  
Date: October 1, 2006  
By: John Contractor

Fresh Air Corporation

## Project Information

For: Mr. and Ms. Smith  
1 Easy Lane, Perfect, ST 12345  
Phone: 555-555-5555 Fax: 555-555-5556  
Email: smiths@email.com

## Design Information

Total floor area:	1750 ft <sup>2</sup>	Design temperature:	63 °F
Radiantly heated area:	555 ft <sup>2</sup>	Maximum supply temperature:	76 °F
Total panel area:	555 ft <sup>2</sup>	Total flow rate:	0.57 gpm
Total tubing area:	547 ft <sup>2</sup>	Maximum head loss:	1.60 ft H <sub>2</sub> O
Total room load:	1691 Btuh	Total tubing required:	970 ft
Total panel output:	622 Btuh	Number of loops:	7
Total supplemental heat:	1069 Btuh	Number of zones:	1
Total back loss:	152 Btuh	Number of manifolds:	2
Boiler output required:	1842 Btuh		

## Space Heating Information

Room name	Room area (ft <sup>2</sup> )	Air temp (°F)	Room load (Btuh)	Supp. heat (Btuh)	F/C	Panel area (ft <sup>2</sup> )	Tubing area (ft <sup>2</sup> )	Surf. temp. (°F)	Deliv. temp. (°F)	Panel output (Btuh /ft <sup>2</sup> )	Back loss (Btuh /ft <sup>2</sup> )
Living room	150	68	174	0	F	150	148	68	72	1.2	0.3
Dining	140	68	153	153							
Kitchen	165	68	202	0	F	165	163	68	76	1.2	0.3
Bedroom 1	180	68	221	221							
Hall	130	68	71	0	F	130	128	68	72	0.5	0.2
Master	240	68	182	182							
Laundry	77	68	96	96							
Bedroom 2	168	68	147	147							
Master Bath	60	68	84	84							
Office	100	68	62	62							
Room28	230	68	125	125							
Mudroom	110	68	175	0	F	110	108	69	76	1.6	0.3
<b>Totals</b>	<b>1750</b>		<b>1691</b>	<b>1069</b>		<b>555</b>	<b>547</b>				





# Radiant Heating Piping Report

Job: 456  
Date: October 1, 2006  
By: John Contractor

Fresh Air Corporation

## Project Information

For: Mr. and Ms. Smith  
1 Easy Lane, Perfect, ST 12345  
Phone: 555-555-5555 Fax: 555-555-5556  
Email: smiths@email.com

## Piping

Name	Tube size / type	Fluid	Num ftgs	1 Ftg EqLen	Ftg Cv	PipeLen (ft)	TotLen (ft)	Temp (°F)	Flow (gpm)	Head (ft H2O)
Living room-B	3/8" BPEX	Water	1	0	0.00	141	141	71.6	0.2	1.55

## Pump Information

Make		Flow (gpm)	0.6
Model		Head (ft H2O)	1.5
Number of pumps	1 (serial) + 0 (parallel) = 1 (total)		

**NOTE: All pipe sections assumed to be connected in series**



# Radiant Heating Manifold Summary

Job: 456  
 Date: October 1, 2006  
 By: John Contractor

Fresh Air Corporation

## Project Information

For: Mr. and Ms. Smith  
 1 Easy Lane, Perfect, ST 12345  
 Phone: 555-555-5555 Fax: 555-555-5556  
 Email: smiths@email.com

Manifold name: Manifold1 Manifold location:	Loop number			
	1	2	3	4
Name	Living room-A	Living room-B	Hall-A	Hall-B
Heating zone	Entire House	Entire House	Entire House	Entire House
Heated area (ft <sup>2</sup> )	71	79	69	61
Room temperature (°F)	68	68	68	68
Cover R (ft <sup>2</sup> -°F/Btuh)	0.80	0.80	0.80	0.80
Surface temperature (°F)	68	68	68	68
Radiant panel CST	41B0	41B0	41B0	41B0
Radiant panel type	Omega plates	Omega plates	Omega plates	Omega plates
Tube spacing (in)	6.0	6.0	6.0	6.0
Tube type/size	3/8" BPEX	3/8" BPEX	3/8" BPEX	3/8" BPEX
Distance to manifold (ft)	1	1	1	1
Loop length (ft)	127	141	116	104
Temperature drop (°F)	1.1	1.1	4.2	4.2
Flow (gpm)	0.19	0.20	0.02	0.02
Head loss (ft H2O)	1.28	1.60	0.03	0.03
Supply temperature (°F)	72	72	72	72
Balance valve (turns from closed)				

### Totals for Manifold1

Max. head loss (ft H2O)	1.60	Total flow (gpm)	0.43
Valves head in worst loop (ft H2O)		Total panel output (Btuh)	245
Max. supply temp. (°F)	72.2	Total tubing required (ft)	487

continued...



# Radiant Heating Manifold Summary

Job: 456  
 Date: October 1, 2006  
 By: John Contractor

Fresh Air Corporation

## Project Information

For: Mr. and Ms. Smith  
 1 Easy Lane, Perfect, ST 12345  
 Phone: 555-555-5555 Fax: 555-555-5556  
 Email: smiths@email.com


Manifold name: Manifold2  
 Manifold location:

	Loop number			
	1	2	3	
Name	Mudroom	Kitchen-A	Kitchen-B	
Heating zone	Entire House	Entire House	Entire House	
Heated area (ft <sup>2</sup> )	110	84	81	
Room temperature (°F)	68	68	68	
Cover R (ft <sup>2</sup> -°F/Btuh)	0.80	0.80	0.80	
Surface temperature (°F)	69	68	68	
Radiant panel CST	41B0	41B0	41B0	
Radiant panel type	Omega plates	Omega plates	Omega plates	
Tube spacing (in)	6.0	6.0	6.0	
Tube type/size	3/8" BPEX	3/8" BPEX	3/8" BPEX	
Distance to manifold (ft)	1	1	1	
Loop length (ft)	191	148	144	
Temperature drop (°F)	5.8	7.6	7.6	
Flow (gpm)	0.07	0.03	0.03	
Head loss (ft H2O)	0.37	0.07	0.07	
Supply temperature (°F)	76	76	76	
Balance valve (turns from closed)				

### Totals for Manifold2

Max. head loss (ft H2O)	0.37	Total flow (gpm)	0.14
Valves head in worst loop (ft H2O)		Total panel output (Btuh)	377
Max. supply temp. (°F)	75.6	Total tubing required (ft)	482

# Level 2




**Job #: 456**  
**Performed by John Contractor for:**  
 Mr. and Ms. Smith  
 1 Easy Lane  
 Perfect, ST 12345  
 Phone: 555-555-5555 Fax: 555-555-5556  
 smiths@email.com

**Fresh Air Corporation**  
 1 Cool Lane  
 Perfect, ST 12345  
 Phone: 555-123-4567 Fax: 555-765-4321  
 www.freshair.com freshair@freshair.com

**Scale: 1 : 60**  
 Page 1  
 Right-Suite Residential  
 6.0.101 RSR44403  
 2007-Mar-22 10:34:12  
 C:\Documents and Settings\jpeabody\ID...

# Level 1



**Job #: 456**  
**Performed by John Contractor for:**  
Mr. and Ms. Smith  
1 Easy Lane  
Perfect, ST 12345  
Phone: 555-555-5555 Fax: 555-555-5556  
smiths@email.com

**Fresh Air Corporation**  
1 Cool Lane  
Perfect, ST 12345  
Phone: 555-123-4567 Fax: 555-765-4321  
www.freshair.com freshair@freshair.com

Scale: 1 : 60  
Page 2  
Right-Suite Residential  
6.0.101 RSR44403  
2007-Mar-22 10:34:12  
C:\Documents and Settings\jpeabody\ID...



Gilles Legault  
CB Supplies  
2594 Le Corbusier  
Laval, QC H7S 2K8  
Phone: 450-687-7842  
Fax: 450-687-5463  
Email: gilles.legault@cbsupplies.ca

## Circuit Schedule

Project #: Sous-sol Mario

February 27, 2017

### Project Information

Project #: Sous-sol Mario

Notes: Empire Mario

Name: Laval Sylvain

Location:

### Circuit Stock Summary

Part Number	Description	Quantity
793005250	1/2 X 250 VIPERT OXY BARRIER	3
7930051000	1/2 X 1000 VIPERT OXY BARRIER	1

### Coil Summary

Coil	Part Number	Coil Length (ft)	Tube Type	Length Used (ft)
Coil 1	793005250	250	1/2" VIPERT OXY BARRIER	205
Coil 2	7930051000	1,000	1/2" VIPERT OXY BARRIER	972
Coil 3	793005250	250	1/2" VIPERT OXY BARRIER	219
Coil 4	793005250	250	1/2" VIPERT OXY BARRIER	186

### Circuits Cut Schedule

#### Basement

Circuit	Length (ft)	Location	Coil
A-1	286	Basement;Manifold 1;Salle de jeux	Coil 2
A-2	186	Basement;Manifold 1;Salle de jeux	Coil 4
A-3	205	Basement;Manifold 1;Ch. Maîtres	Coil 1
A-4	271	Basement;Manifold 1;Ch. Maîtres	Coil 2
A-5	219	Basement;Manifold 1;Salle de bain	Coil 3
A-6	130	Basement;Manifold 1;Chambre 4	Coil 2
A-7	284	Basement;Manifold 1;Chambre 4	Coil 2

IN NO EVENT WILL AVENIR SOFTWARE INC. ("AVENIR") OR ITS AFFILIATES BE LIABLE UNDER ANY CONTRACT, NEGLIGENCE, STRICT LIABILITY OR OTHER LEGAL OR EQUITABLE THEORY FOR ANY CONSEQUENTIAL, INCIDENTAL, INDIRECT OR SPECIAL OR PUNITIVE DAMAGES WHATSOEVER (INCLUDING, BUT NOT LIMITED TO, DAMAGES FOR LOSS OF BUSINESS PROFITS, BUSINESS INTERRUPTION, LOSS OF BUSINESS INFORMATION OR DATA AND THE LIKE), EVEN IF SUCH PARTY HAS BEEN ADVISED OF THE POSSIBILITY OF SUCH DAMAGES. AVENIR'S CUMULATIVE LIABILITY FROM ANY CAUSE RELATED TO OR ARISING FROM THE USE THIS REPORT, AND REGARDLESS OF THE FORM OF THE ACTION, SHALL BE LIMITED TO NO GREATER THAN THE AMOUNT OF FEES PAID TO AVENIR UNDER THE SOFTWARE LICENSE AGREEMENT.

Created Using LoopCAD 2016 CB Supplies Ltd. (CAD)  
(2/27/2017)


Version:16.0.0582

## Disclaimers

The calculated values shown in this report are based on the data input by the user of the software. Inaccurate or erroneous data input will result in inaccurate or erroneous results. You are strongly advised to review all input data carefully, and to have the calculated results reviewed by an experienced heating professional to ensure reasonableness and suitability for your application.

DISCLAIMER:  
 Note: Details of the tubing bend radius have been simplified for clarity. Consult tubing manufacturer for specific bend radius recommendations.

Circuit Information										
Number	Length (ft)	Tube Size	Manifold	Flow (USGPM)	Head Loss (ft water)	Total Load (Btu/hr)	Tube Type	Design ΔT (°F)	Fluid	Supply Temp (°F)
A-1	286	1/2"	Manifold 1	0.43	3.1	4,112	1/2" VIPERT OXY BARRIER	20	30% Propylene Glycol	116
A-2	186	1/2"	Manifold 1	0.38	1.6	3,575	1/2" VIPERT OXY BARRIER	20	30% Propylene Glycol	116
A-3	205	1/2"	Manifold 1	0.41	2.0	3,815	1/2" VIPERT OXY BARRIER	20	30% Propylene Glycol	116
A-4	271	1/2"	Manifold 1	0.33	1.8	3,092	1/2" VIPERT OXY BARRIER	20	30% Propylene Glycol	116
A-5	219	1/2"	Manifold 1	0.31	1.3	2,896	1/2" VIPERT OXY BARRIER	20	30% Propylene Glycol	116
A-6	130	1/2"	Manifold 1	0.25	0.6	2,324	1/2" VIPERT OXY BARRIER	20	30% Propylene Glycol	116
A-7	284	1/2"	Manifold 1	0.36	2.2	3,442	1/2" VIPERT OXY BARRIER	20	30% Propylene Glycol	116



PROJECT: **Laval Sylvain**  
 CUSTOMER:

PROJECT NO.: **Sous-sol Mario**

SCALE: **1/8"=1'**

DRAWING NAME: **P1 (Basement)**

DRAWN BY: **Gilles Legault**  
Created Using LogiCAD 2016 16.0.0562 (2/27/2017)

DATE: **2/27/2017**

**REVISIONS**

No	Desc	Date





Gilles Legault  
 CB Supplies  
 2594 Le Corbusier  
 Laval, QC H7S 2K8  
 Phone: 450-687-7842  
 Fax: 450-687-5463  
 Email: gilles.legault@cbsupplies.ca

**Heat Loss Summary**  
 User Entered (Manual) Load Calculation  
 Project #: Sous-sol Mario  
 February 27, 2017

## Project Information

Project #: Sous-sol Mario  
 Name: Laval Sylvain  
 Location:

Notes: Empire Mario

## Load Calculation Summary

Load Calculation Method:	User Entered (Manual)	Component Losses:	19,381 Btu/hr
Floorplans / Levels:		Radiant Back Losses:	3,876 Btu/hr
Basement	1,113 ft <sup>2</sup>	Total Heating Load:	23,257 Btu/hr
Total Area:	1,113 ft <sup>2</sup>		
		Radiant Heating:	19,381 Btu/hr
		Radiant Back Losses:	3,876 Btu/hr
		Total Heating Load:	23,257 Btu/hr

## Load Calculation Results

### Total Project

Room	Area	Heating Type	Room Temp	Walls	Windows	Doors	Skylights	Floor	Ceiling	Infiltration	Additional	Recovered Panel Loss	Design Load	Unit Loss
Total For Project	1,113	RH	70.0	0	0	0	0	3,876	0	0	0	0	23,257	24

### Basement

#### Slab Below Grade Construction

Room	Area	Heating Type	Room Temp	Walls	Windows	Doors	Skylights	Floor	Ceiling	Infiltration	Additional	Recovered Panel Loss	Design Load	Unit Loss
Ch. Maîtres	248	RH (M)	70.0	0	0	0	0	857	0	0	0	0	5,142	24
Chambre 4	257	RH (M)	70.0	0	0	0	0	877	0	0	0	0	5,265	24
Mécanique	103	NH	70.0	0	0	0	0	0	0	0	0	0	0	0
Salle de bain	119	RH (M)	70.0	0	0	0	0	387	0	0	0	0	2,324	24
Salle de jeux	490	RH (M)	70.0	0	0	0	0	1,754	0	0	0	0	10,526	24
Sub Total	1,113	RH (M)	70.0	0	0	0	0	3,876	0	0	0	0	23,257	24

Length = ft Area = ft<sup>2</sup> Temperature = °F Flowrate = USGPM Heat Loss = Btu/hr Unit Heat Loss = Btu/hr-ft<sup>2</sup> Rv = hr-ft<sup>2</sup>-°F/btu  
 Head Loss = ft water RH = Radiant Floor Heating BB = Baseboard FA = Forced Air OTH = Other Heating SM = Snowmelt N = Not Heated

Created Using LoopCAD 2016 CB Supplies Ltd. (CAD)  
 (2/27/2017)  
 Version: 16.0.0582

See end of report for important Notes and Disclaimers.

## Disclaimers

The calculated values shown in this report are based on the data input by the user of the software. Inaccurate or erroneous data input will result in inaccurate or erroneous results. You are strongly advised to review all input data carefully, and to have the calculated results reviewed by an experienced heating professional to ensure reasonableness and suitability for your application.

IN NO EVENT WILL AVENIR SOFTWARE INC. ("AVENIR") OR ITS AFFILIATES BE LIABLE UNDER ANY CONTRACT, NEGLIGENCE, STRICT LIABILITY OR OTHER LEGAL OR EQUITABLE THEORY FOR ANY CONSEQUENTIAL, INCIDENTAL, INDIRECT OR SPECIAL OR PUNITIVE DAMAGES WHATSOEVER (INCLUDING, BUT NOT LIMITED TO, DAMAGES FOR LOSS OF BUSINESS PROFITS, BUSINESS INTERRUPTION, LOSS OF BUSINESS INFORMATION OR DATA AND THE LIKE), EVEN IF SUCH PARTY HAS BEEN ADVISED OF THE POSSIBILITY OF SUCH DAMAGES. AVENIR'S CUMULATIVE LIABILITY FROM ANY CAUSE RELATED TO OR ARISING FROM THE USE THIS REPORT, AND REGARDLESS OF THE FORM OF THE ACTION, SHALL BE LIMITED TO NO GREATER THAN THE AMOUNT OF FEES PAID TO AVENIR UNDER THE SOFTWARE LICENSE AGREEMENT.



Gilles Legault  
 CB Supplies  
 2594 Le Corbusier  
 Laval, QC H7S 2K8  
 Phone: 450-687-7842  
 Fax: 450-687-5463  
 Email: gilles.legault@cbsupplies.ca

# Heating System Detail

Project #: Sous-sol Mario  
 February 27, 2017

## Project Information

Project #: Sous-sol Mario  
 Name: Laval Sylvain  
 Location:

Notes: Empire Mario

## Design Conditions and Summary

Load Calculation Method:	User Entered (Manual)	Total Tubing Lengths:	Component Losses:	19,381 Btu/hr
Floorplans / Levels:		1/2" VIPERT OXY	Radiant Back Losses:	3,876 Btu/hr
Basement	1,113 ft <sup>2</sup>	BARRIER	Total Heating Load:	23,257 Btu/hr
Total Area:	1,113 ft <sup>2</sup>			
		Total RH Circuits:	Radiant Heating:	19,381 Btu/hr
		Total Manifolds:	Radiant Back Losses:	3,876 Btu/hr
		Total Zones:	Total Heating Load:	23,257 Btu/hr
		Fluid Type:	30% Propylene Glycol	
		Total Tubing Volume:	15.18 USG	
		Glycol Volume (30%):	4.55 USG	

## Zone Heating Summary

Zone #	Area	Heating Types	RH Circuits	Flowrate	Head Loss	Supplemental	Rooms
101	1,113	RH (M)	7	2.47	4.1	0	Salle de jeux, Chambre 4, Ch. Maîtres, Salle de bain
Total	1,113	RH (M)	7	2.47	4.1	0	

\*RH Loads include internal panel back loss that may not be included in the project total.

Length = ft Area = ft<sup>2</sup> Temperature = °F Flowrate = USGPM Heat Loss = Btu/hr Unit Heat Loss = Btu/hr-ft<sup>2</sup> Rv = hr-ft<sup>2</sup>-°F/btu  
 Head Loss = ft water RH = Radiant Floor Heating BB = Baseboard FA = Forced Air OTH = Other Heating SM = Snowmelt N = Not Heated

Created Using LoopCAD 2016 CB Supplies Ltd. (CAD)  
 (2/27/2017)  
 Version: 16.0.0582

See end of report for important Notes and Disclaimers.

**Room Heating Summary**

**Basement**

**Ch. Maîtres**

Total Area: 248 ft<sup>2</sup>  
 Heated by: RH (M)  
 Room Temperature: 70 °F  
 Floor Covering (Rv): 0.5

Radiant Heating:  
 Heated Area: 214 ft<sup>2</sup>  
 Tubing in Floor: 476 ft  
 Circuits in Room: 2  
 Tube Spacing: 6/12  
 Required Surface Temp: 81 °F  
 Required Water Temp: 116 °F  
 Est. Peak Output: 4,582 Btu/hr

Load/Loss Summary:  
**Room Design Load:** 4,285 Btu/hr  
 Radiant Load: 5,142 Btu/hr  
 Baseboard Load: 0 Btu/hr  
 Forced Air Load: 0 Btu/hr  
 Other Load: 0 Btu/hr  
 Radiant Back Loss: 857 Btu/hr  
 Recovered Back Loss: 0 Btu/hr  
 Total Heat Loss: 5,142 Btu/hr

**Chambre 4**

Total Area: 257 ft<sup>2</sup>  
 Heated by: RH (M)  
 Room Temperature: 70 °F  
 Floor Covering (Rv): 0.5

Radiant Heating:  
 Heated Area: 215 ft<sup>2</sup>  
 Tubing in Floor: 415 ft  
 Circuits in Room: 2  
 Tube Spacing: 9  
 Required Surface Temp: 81 °F  
 Required Water Temp: 116 °F  
 Est. Peak Output: 4,684 Btu/hr

Load/Loss Summary:  
**Room Design Load:** 4,387 Btu/hr  
 Radiant Load: 5,265 Btu/hr  
 Baseboard Load: 0 Btu/hr  
 Forced Air Load: 0 Btu/hr  
 Other Load: 0 Btu/hr  
 Radiant Back Loss: 877 Btu/hr  
 Recovered Back Loss: 0 Btu/hr  
 Total Heat Loss: 5,265 Btu/hr

**Mécanique**

Total Area: 103 ft<sup>2</sup>  
Heated by: NH  
Room Temperature: 70 °F  
Floor Covering (Rv): 0.5

Radiant Heating:  
Heated Area: 86 ft<sup>2</sup>  
Tubing in Floor: 0 ft  
Circuits in Room: 0  
Tube Spacing: 12  
Required Surface Temp: 70 °F  
Required Water Temp: 115 °F  
Est. Peak Output: 0 Btu/hr

Load/Loss Summary:  
**Room Design Load:** 0 Btu/hr  
Radiant Load: 0 Btu/hr  
Baseboard Load: 0 Btu/hr  
Forced Air Load: 0 Btu/hr  
Other Load: 0 Btu/hr  
Radiant Back Loss: 0 Btu/hr  
Recovered Back Loss: 0 Btu/hr  
Total Heat Loss: 0 Btu/hr

**Salle de bain**

Total Area: 119 ft<sup>2</sup>  
Heated by: RH (M)  
Room Temperature: 70 °F  
Floor Covering (Rv): 0.5

Radiant Heating:  
Heated Area: 97 ft<sup>2</sup>  
Tubing in Floor: 219 ft  
Circuits in Room: 1  
Tube Spacing: 6/12  
Required Surface Temp: 81 °F  
Required Water Temp: 112 °F  
Est. Peak Output: 2,141 Btu/hr

Load/Loss Summary:  
**Room Design Load:** 1,937 Btu/hr  
Radiant Load: 2,324 Btu/hr  
Baseboard Load: 0 Btu/hr  
Forced Air Load: 0 Btu/hr  
Other Load: 0 Btu/hr  
Radiant Back Loss: 387 Btu/hr  
Recovered Back Loss: 0 Btu/hr  
Total Heat Loss: 2,324 Btu/hr

**Salle de jeux**

Total Area: 490 ft<sup>2</sup>  
Heated by: RH (M)  
Room Temperature: 70 °F  
Floor Covering (Rv): 0.5

Radiant Heating:  
Heated Area: 439 ft<sup>2</sup>  
Tubing in Floor: 472 ft  
Circuits in Room: 2  
Tube Spacing: 9  
Required Surface Temp: 81 °F  
Required Water Temp: 115 °F  
Est. Peak Output: 9,581 Btu/hr

Load/Loss Summary:  
**Room Design Load:** 8,772 Btu/hr  
Radiant Load: 10,526 Btu/hr  
Baseboard Load: 0 Btu/hr  
Forced Air Load: 0 Btu/hr  
Other Load: 0 Btu/hr  
Radiant Back Loss: 1,754 Btu/hr  
Recovered Back Loss: 0 Btu/hr  
Total Heat Loss: 10,526 Btu/hr

## Radiant Heating Details

### Manifold Summary

Manifold Name	Zones	Circuits	Flowrate	Head Loss <sup>1</sup>	Required Temp.	Supplied Temp.	Temp Drop	Manifold Type	Control Type	Actuators
Manifold 1	1	7	2.47	4.1	116	116	20 (22)	CB Supplies 1" Pre-Assembled Manifold	Manifold	0
Total	1	7	2.47	4.1	116	-	-	-	-	0

<sup>1</sup>Total Head loss includes manifold and circuit head loss

## Tubing Circuit Details

### Manifold 1

Circuit	Rooms Served	Total Length	Tube Spacing	Area Covered	Tubing	Flowrate	Head Loss**	Temp Drop	Load	Actuator
A-1	Salle de jeux	286	8	178	1/2" VIPERT OXY BARRIER	0.43	3.1	20 (22)	4,112	No
A-2	Salle de jeux	186	11	156	1/2" VIPERT OXY BARRIER	0.38	1.6	20 (21)	3,575	No
A-3	Ch. Maîtres	205	10	169	1/2" VIPERT OXY BARRIER	0.41	2.0	20 (20)	3,815	No
A-4	Ch. Maîtres	271	12/6	139	1/2" VIPERT OXY BARRIER	0.33	1.8	20 (22)	3,092	No
A-5	Salle de bain	219	12/6	130	1/2" VIPERT OXY BARRIER	0.31	1.3	20 (22)	2,896	No
A-6	Chambre 4	130	11	114	1/2" VIPERT OXY BARRIER	0.25	0.6	20 (20)	2,324	No
A-7	Chambre 4	284	7	165	1/2" VIPERT OXY BARRIER	0.36	2.2	20 (22)	3,442	No
Total	-	1,582		1,051	-	2.47	3.1		23,257	0

\*\* Head loss for circuit tubing only

## Disclaimers

The calculated values shown in this report are based on the data input by the user of the software. Inaccurate or erroneous data input will result in inaccurate or erroneous results. You are strongly advised to review all input data carefully, and to have the calculated results reviewed by an experienced heating professional to ensure reasonableness and suitability for your application.

IN NO EVENT WILL AVENIR SOFTWARE INC. ("AVENIR") OR ITS AFFILIATES BE LIABLE UNDER ANY CONTRACT, NEGLIGENCE, STRICT LIABILITY OR OTHER LEGAL OR EQUITABLE THEORY FOR ANY CONSEQUENTIAL, INCIDENTAL, INDIRECT OR SPECIAL OR PUNITIVE DAMAGES WHATSOEVER (INCLUDING, BUT NOT LIMITED TO, DAMAGES FOR LOSS OF BUSINESS PROFITS, BUSINESS INTERRUPTION, LOSS OF BUSINESS INFORMATION OR DATA AND THE LIKE), EVEN IF SUCH PARTY HAS BEEN ADVISED OF THE POSSIBILITY OF SUCH DAMAGES. AVENIR'S CUMULATIVE LIABILITY FROM ANY CAUSE RELATED TO OR ARISING FROM THE USE THIS REPORT, AND REGARDLESS OF THE FORM OF THE ACTION, SHALL BE LIMITED TO NO GREATER THAN THE AMOUNT OF FEES PAID TO AVENIR UNDER THE SOFTWARE LICENSE AGREEMENT.



Gilles Legault  
CB Supplies  
2594 Le Corbusier  
Laval, QC H7S 2K8  
Phone: 450-687-7842  
Fax: 450-687-5463  
Email: gilles.legault@cbsupplies.ca

## Quotation

Project #: Sous-sol Mario  
February 27, 2017

### Project Information

Project #: Sous-sol Mario  
Name: Laval Sylvain  
Location:

Notes: Empire Mario

### Quotation For

### Project Summary

Load Calculation Method:	User Entered (Manual)	Total Heating Load:	23,257 Btu/hr
Floorplans / Levels:	1	Total RH Circuits:	7
Total Area:	1,113 ft <sup>2</sup>	Total Manifolds:	1
		Total Zones:	2

### Comments

voir devis en annexe

IN NO EVENT WILL AVENIR SOFTWARE INC. ("AVENIR") OR ITS AFFILIATES BE LIABLE UNDER ANY CONTRACT, NEGLIGENCE, STRICT LIABILITY OR OTHER LEGAL OR EQUITABLE THEORY FOR ANY CONSEQUENTIAL, INCIDENTAL, INDIRECT OR SPECIAL OR PUNITIVE DAMAGES WHATSOEVER (INCLUDING, BUT NOT LIMITED TO, DAMAGES FOR LOSS OF BUSINESS PROFITS, BUSINESS INTERRUPTION, LOSS OF BUSINESS INFORMATION OR DATA AND THE LIKE), EVEN IF SUCH PARTY HAS BEEN ADVISED OF THE POSSIBILITY OF SUCH DAMAGES. AVENIR'S CUMULATIVE LIABILITY FROM ANY CAUSE RELATED TO OR ARISING FROM THE USE THIS REPORT, AND REGARDLESS OF THE FORM OF THE ACTION, SHALL BE LIMITED TO NO GREATER THAN THE AMOUNT OF FEES PAID TO AVENIR UNDER THE SOFTWARE LICENSE AGREEMENT.

Created Using LoopCAD 2016 CB Supplies Ltd. (CAD)  
(2/27/2017)  
Version:16.0.0582



## Goods & Services Supplied

### Tubing

Part Number	Description	Quantity	Unit
793005250	1/2 X 250 VIPERT OXY BARRIER	3	Ea
7930051000	1/2 X 1000 VIPERT OXY BARRIER	1	Ea

### Manifolds/Fittings

Part Number	Description	Quantity	Unit
762910007	7 Loop Manif. x 1 w/Vlvs+Meter VGMC347S	1	Ea

### Tools/Accessories

Part Number	Description	Quantity	Unit
760000005	R2012CP 1/2 COMP X MANIFOLD 220E000403	14	Ea
767010114AF	TH114-AF-24T NON-PROG AMB/FLR THERMOSTAT	1	Ea
763006005	1/2 PLASTIC BEND SUPPORT HRSL3 15107	14	Ea

## Disclaimers

The calculated values shown in this report are based on the data input by the user of the software. Inaccurate or erroneous data input will result in inaccurate or erroneous results. You are strongly advised to review all input data carefully, and to have the calculated results reviewed by an experienced heating professional to ensure reasonableness and suitability for your application.

IN NO EVENT WILL AVENIR SOFTWARE INC. ("AVENIR") OR ITS AFFILIATES BE LIABLE UNDER ANY CONTRACT, NEGLIGENCE, STRICT LIABILITY OR OTHER LEGAL OR EQUITABLE THEORY FOR ANY CONSEQUENTIAL, INCIDENTAL, INDIRECT OR SPECIAL OR PUNITIVE DAMAGES WHATSOEVER (INCLUDING, BUT NOT LIMITED TO, DAMAGES FOR LOSS OF BUSINESS PROFITS, BUSINESS INTERRUPTION, LOSS OF BUSINESS INFORMATION OR DATA AND THE LIKE), EVEN IF SUCH PARTY HAS BEEN ADVISED OF THE POSSIBILITY OF SUCH DAMAGES. AVENIR'S CUMULATIVE LIABILITY FROM ANY CAUSE RELATED TO OR ARISING FROM THE USE THIS REPORT, AND REGARDLESS OF THE FORM OF THE ACTION, SHALL BE LIMITED TO NO GREATER THAN THE AMOUNT OF FEES PAID TO AVENIR UNDER THE SOFTWARE LICENSE AGREEMENT.

Created Using LoopCAD 2016 CB Supplies Ltd. (CAD)  
(2/27/2017)  
Version:16.0.0582



Gilles Legault  
CB Supplies  
2594 Le Corbusier  
Laval, QC H7S 2K8  
Phone: 450-687-7842  
Fax: 450-687-5463  
Email: gilles.legault@cbsupplies.ca

# Water Supply Summary

Project #: Sous-sol Mario  
February 27, 2017

## Project Information

Project #: Sous-sol Mario  
Name: Laval Sylvain  
Location:

Notes: Empire Mario

## Supply Summary

Name	Temp	Total Flow	Head Loss <sup>1</sup>	Load	# Circuits	# Zones
Water Temperature	116.1	2.47	4.1	23,257	7	1

(1) Head loss includes manifolds, circuits, and supply/return piping if specified, may also contain control valve losses.

## Manifold Summary

Manifold Name	Circuits	Flowrate	Required Temp.	Supplied Temp.	Manifold Type	Manifold Head Loss	Circuit Head Loss	Total Head Loss <sup>2</sup>
Manifold 1	7	2.47	116	116	CB Supplies 1" Pre-Assembled Manifold	1.0	3.1	4.1
Total	7	2.47	116	-	-			4.1

, (2) Total Head loss includes manifold and circuit head loss.

**Water Temperature ( 116 °F )**

**Manifold 1 ( 116 °F, CB Supplies 1" Pre-Assembled Manifold, 7 Circuits )**

Circuit	Rooms Served	Total Length	Tube Spacing	Area Covered	Tubing	Flowrate	Head Loss <sup>1</sup>	Temp Drop <sup>2</sup>	Load <sup>3</sup>	Actuator
A-1	Salle de jeux	286		171	1/2" VIPERT OXY BARRIER	0.43	3.1	20 (22)	4,112	No
A-2	Salle de jeux	186		149	1/2" VIPERT OXY BARRIER	0.38	1.6	20 (21)	3,575	No
A-3	Ch. Maîtres	205		159	1/2" VIPERT OXY BARRIER	0.41	2.0	20 (20)	3,815	No
A-4	Ch. Maîtres	271	6 - 12	129	1/2" VIPERT OXY BARRIER	0.33	1.8	20 (22)	3,092	No
A-5	Salle de bain	219	6 - 12	121	1/2" VIPERT OXY BARRIER	0.31	1.3	20 (22)	2,896	No
A-6	Chambre 4	130		95	1/2" VIPERT OXY BARRIER	0.25	0.6	20 (20)	2,324	No
A-7	Chambre 4	284		141	1/2" VIPERT OXY BARRIER	0.36	2.2	20 (22)	3,442	No
Total	-	1,582		965	-	2.47	3.1		23,257	0

(1) Head loss for circuit tubing only. (2) Design Temp Drop (Estimated Actual Drop). (3) Load includes circuit back loss.

**Disclaimers**

The calculated values shown in this report are based on the data input by the user of the software. Inaccurate or erroneous data input will result in inaccurate or erroneous results. You are strongly advised to review all input data carefully, and to have the calculated results reviewed by an experienced heating professional to ensure reasonableness and suitability for your application.

IN NO EVENT WILL AVENIR SOFTWARE INC. ("AVENIR") OR ITS AFFILIATES BE LIABLE UNDER ANY CONTRACT, NEGLIGENCE, STRICT LIABILITY OR OTHER LEGAL OR EQUITABLE THEORY FOR ANY CONSEQUENTIAL, INCIDENTAL, INDIRECT OR SPECIAL OR PUNITIVE DAMAGES WHATSOEVER (INCLUDING, BUT NOT LIMITED TO, DAMAGES FOR LOSS OF BUSINESS PROFITS, BUSINESS INTERRUPTION, LOSS OF BUSINESS INFORMATION OR DATA AND THE LIKE), EVEN IF SUCH PARTY HAS BEEN ADVISED OF THE POSSIBILITY OF SUCH DAMAGES. AVENIR'S CUMULATIVE LIABILITY FROM ANY CAUSE RELATED TO OR ARISING FROM THE USE THIS REPORT, AND REGARDLESS OF THE FORM OF THE ACTION, SHALL BE LIMITED TO NO GREATER THAN THE AMOUNT OF FEES PAID TO AVENIR UNDER THE SOFTWARE LICENSE AGREEMENT.